

Water Quality Test Result of Drinking Water Fountain

Building	Location	Sampling Date	Results				
			Cold water				Hot water
			Lead (µg/L)	Chlorine (mg/L)	Total coliform count (mpn/100ml)	<i>E.coli</i> count (mpn/100ml)	Lead (µg/L)
E2	G003	06/01/2020	0.144	<0.02	0	0	0.222
	G029		0.324	<0.02	0	0	0.343
	1004		0.181	<0.02	0	0	0.533
	1040		0.347	<0.02	0	0	0.510
	2004		0.107	<0.02	0	0	0.238
	2045		0.223	0.02	0	0	0.430
	3005		0.385	<0.02	0	0	0.679
	3033		0.612	<0.02	0	0	0.641
	4005		0.221	<0.02	0	0	0.478
	4033		0.230	<0.02	0	0	0.568
E3	1L07	13/01/2020	0.247	<0.02	0	0	0.691
	2L07		0.088	<0.02	0	0	0.183
	3L07		0.087	<0.02	0	0	0.246
	4L05		1.261	<0.02	0	0	1.302
E4	GL09	13/01/2020	0.095	<0.02	0	0	0.091
	1L09		0.100	<0.02	0	0	0.178
	3L10		0.167	<0.02	0	0	0.269
E5	GL12	13/01/2020	0.051	<0.02	0	0	0.070
E6	GL15	13/01/2020	0.106	<0.02	0	0	0.068
	1L18		0.175	<0.02	0	0	0.199
	2L18		0.234	<0.02	0	0	0.314
	3L15		0.376	<0.02	0	0	0.409

Reference standard: VMA from Decreto-Lei n.º 46/96/M, Aprova o Regulamento de Águas e de Drenagem de Águas Residuais de Macau
Lead: <0.05mg/L(<50µg/L); Chlorine: <0.5mg/L; Total coliform count: 0 mpn/100ml; *E.coli* count: 0 mpn/100ml

Water Quality Test Result of Drinking Water Fountain

Building	Location	Sampling Date	Results				
			Cold water				Hot water
			Lead (µg/L)	Chlorine (mg/L)	Total coliform count (mpn/100ml)	<i>E.coli</i> count (mpn/100ml)	Lead (µg/L)
E11	GL04	20/01/2020	0.137	<0.02	0	0	0.095
	1L04		0.591	<0.02	0	0	0.139
	1J02		0.153	<0.02	0	0	0.233
	2L04		0.261	<0.02	0	0	0.191
	2L08		0.073	<0.02	0	0	0.151
	3L04		0.098	<0.02	0	0	0.312
	3091		0.140	<0.02	0	0	0.186
E12	GL05	20/01/2020	0.112	<0.02	0	0	0.164
	1058		0.107	<0.02	0	0	0.212
	1L01		0.090	<0.02	0	0	0.170
	2081		0.182	<0.02	0	0	0.171
	3086		0.124	<0.02	0	0	0.115

Reference standard: VMA from Decreto-Lei n.º 46/96/M, Aprova o Regulamento de Águas e de Drenagem de Águas Residuais de Macau
 Lead: <0.05mg/L(<50µg/L); Chlorine: <0.5mg/L; Total coliform count: 0 mpn/100ml; *E.coli* count: 0 mpn/100ml