

## 飲水機水質測試結果

地點/大樓	位置	採樣日期	結果				
			冷水				熱水
			鉛 (µg/L)	氯 (mg/L)	大腸菌群 (mpn/100ml)	埃希氏大腸桿菌 (mpn/100ml)	鉛 (µg/L)
S3	C1-1040	01 & 08/06/2020	0.358	<0.02	0	0	0.513
	C1-2040		0.657	<0.02	0	0	0.760
	C1-3040		0.077	<0.02	0	0	0.333
	C1-4040		0.159	<0.02	0	0	0.694
	C1-5040		1.380	<0.02	0	0	2.220
	C1-6040		0.335	<0.02	0	0	0.447
	C1-7040		0.308	<0.02	0	0	0.545
	C1-8040		0.403	<0.02	0	0	0.478
	C1-9012		1.128	<0.02	0	0	0.525
	C2-1009		0.484	<0.02	0	0	0.534
	C2-2009		0.325	<0.02	0	0	0.459
	C2-4009		0.198	<0.02	0	0	0.630
	C2-5009		0.297	<0.02	0	0	0.927
	C2-6009		0.761	<0.02	0	0	1.028
	C2-7009		0.216	<0.02	0	0	0.403
	C2-8009		0.142	<0.02	0	0	0.318
	C3-1060		0.145	<0.02	0	0	0.256
	C3-2060		0.585	<0.02	0	0	0.475
	C3-3060		0.512	<0.02	0	0	0.690
	C3-4060		0.268	<0.02	0	0	0.370
	C3-5060		6.357	<0.02	0	0	8.467
	C3-6060		0.200	<0.02	0	0	0.443
	C3-7060		0.812	<0.02	0	0	1.616
	C3-8060		0.262	<0.02	0	0	0.523

參考標準值: 澳門政府第46/96/M號法令〈澳門供排水規章〉可接受最大值  
 鉛: <0.05mg/L (<50µg/L); 氯: <0.5mg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml

## 飲水機水質測試結果

地點/大樓	位置	採樣日期	結果				
			冷水				熱水
			鉛 (µg/L)	氯 (mg/L)	大腸菌群 (mpn/100ml)	埃希氏大腸桿菌 (mpn/100ml)	鉛 (µg/L)
S4	1001	08/06/2020	0.577	<0.02	0	0	0.076
	2001		0.243	<0.02	0	0	0.214
	4001		0.139	<0.02	0	0	0.217
	5001		0.073	<0.02	0	0	0.176
	6001		0.238	<0.02	0	0	0.254
	7001		0.100	<0.02	0	0	0.169
	8001		0.149	<0.02	0	0	0.672
	9001		0.110	<0.02	0	0	0.203
	10001		0.070	<0.02	0	0	0.281

參考標準值: 澳門政府第46/96/M號法令〈澳門供排水規章〉可接受最大值  
 鉛: <0.05mg/L (<50µg/L); 氯: <0.5mg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml